chemiphar
LABORATORY

Kampala, 21st September 2020

Spouts of Water Ltd
Attn: Quality Assurance Manager
Busiro Block 376, Plot 895
P.O Box 12042 Kampala
Wakiso, Uganda

Dear Customer,

Please find enclosed the results for the requested analysis of the sample.

Sample received on:	16th September 2020
Customer's Description:	Ceramic Water 3 Ltr Filter
Our reference:	20/09/220 (Spiked Water Sample)
Sampling by:	Customer
Start analysis:	17th September 2020
Page:	1/1

Certificate of Analysis

Microbiology:

Parameter	Method	Units	Results
Pathogens			
Total coliforms	ISO 9308-1	cfu/100ml	2.5×10^2
Escherichia coli	ISO 9308-1	cfu/100ml	1.0×10^2

Thanking you for your confidence,

Yours Sincerely,

Winnie Nakaayi Kiwanuka
Quality Assurance Manager

Julius Mbabazi
Head of Laboratory

Test results mentioned on this certificate relate only to the item tested.
The results apply to the sample as received.
Test results shall not be reproduced except in full, without a written approval of Chemiphar (U) Limited.
Chemiphar (U) Limited. Guarantees that all above mentioned results are obtained by use of methods identical or equal to official recognised test methods. The codes mentioned under Method refer to an Internal Identification or Standard test method used.
Data concerning the measurement uncertainty of the test methods (if applicable) is available in the laboratory.

If you have any doubt about the authenticity of this Certificate, please e-mail us at info@chemiphar.net

chemiphar
LABORATORY

Kampala, 21st September 2020

Spouts of Water Ltd
Attn: Quality Assurance Manager
Busiro Block 376, Plot 895
P.O Box 12042 Kampala
Wakiso, Uganda

Dear Customer,

Please find enclosed the results for the requested analysis of the sample.

Sample received on:	16th September 2020
Customer's Description:	Ceramic Water 3 Ltr Filter
Our reference:	20/09/220 (Filtrate)
Sampling by:	Customer
Start analysis:	17th September 2020
Page:	1/1

Certificate of Analysis

Microbiology:

Parameter	Method	Units	Results
Pathogens			
Total coliforms	ISO 9308-1	cfu/100ml	0
Escherichia coli	ISO 9308-1	cfu/100ml	0

Thanking you for your confidence,

Yours Sincerely,

Winnie Nakaayi Kiwanuka
Quality Assurance Manager

Julius Mbabazi
Head of Laboratory

Test results mentioned on this certificate relate only to the item tested.
The results apply to the sample as received.
Test results shall not be reproduced except in full, without a written approval of Chemiphar (U) Limited.
Chemiphar (U) Limited. Guarantees that all above mentioned results are obtained by use of methods identical or equal to official recognised test methods. The codes mentioned under Method refer to an Internal Identification or Standard test method used.
Data concerning the measurement uncertainty of the test methods (if applicable) is available in the laboratory.

If you have any doubt about the authenticity of this Certificate, please e-mail us at info@chemiphar.net

chemiphar
LABORATORY

Kampala, 21st September 2020

Spouts of Water Ltd
Attn: Quality Assurance Manager
Busiro Block 376, Plot 895
P.O Box 12042 Kampala
Wakiso, Uganda

Dear Customer,

Please find enclosed the results for the requested analysis of the sample.

Sample received on:	16th September 2020
Customer's Description:	Ceramic Water 5.5 Ltr Filter
Our reference:	20/09/221 (Spiked Water Sample)
Sampling by:	Customer
Start analysis:	17th September 2020
Page:	1/1

Certificate of Analysis

Microbiology:

Parameter	Method	Units	Results
Pathogens			
Total coliforms	ISO 9308-1	cfu/100ml	2.5×10^2
Escherichia coli	ISO 9308-1	cfu/100ml	1.0×10^2

Thanking you for your confidence,

Yours Sincerely,

Winnie Nakaayi Kiwanuka
Quality Assurance Manager

Julius Mbabazi
Head of Laboratory

Test results mentioned on this certificate relate only to the item tested.
The results apply to the sample as received.
Test results shall not be reproduced except in full, without a written approval of Chemiphar (U) Limited.
Chemiphar (U) Limited. Guarantees that all above mentioned results are obtained by use of methods identical or equal to official recognised test methods. The codes mentioned under Method refer to an Internal Identification or Standard test method used.
Data concerning the measurement uncertainty of the test methods (if applicable) is available in the laboratory.

If you have any doubt about the authenticity of this Certificate, please e-mail us at info@chemiphar.net

Chemiphar (Uganda) Limited
P.O.Box 25525 Kampala ▪ Plot 224-226, Kyeyune Road ▪ Kiggundu Zone ▪ Kansanga
Tel.: +256-(0)392-268 832 ▪ Mob: +256-(0) 756-502 315 ▪ email: info@chemiphar.net
www.chemiphar.net ▪ VAT : 25639-J ▪ TIN : 1000033827

chemiphar
LABORATORY

Kampala, 21st September 2020

Spouts of Water Ltd
Attn: Quality Assurance Manager
Busiro Block 376, Plot 895
P.O Box 12042 Kampala
Wakiso, Uganda

Dear Customer,

Please find enclosed the results for the requested analysis of the sample.

Sample received on:	16th September 2020
Customer's Description:	Ceramic Water 5.5 Ltr Filter
Our reference:	20/09/221 (Filtrate)
Sampling by:	Customer
Start analysis:	17th September 2020
Page:	1/1

Certificate of Analysis

Microbiology:

Parameter	Method	Units	Results
Pathogens			
Total coliforms	ISO 9308-1	cfu/100ml	0
Escherichia coli	ISO 9308-1	cfu/100ml	0

Thanking you for your confidence,

Yours Sincerely,

Winnie Nakaayi Kiwanuka
Quality Assurance Manager

Julius Mbabazi
Head of Laboratory

Test results mentioned on this certificate relate only to the item tested.
The results apply to the sample as received.
Test results shall not be reproduced except in full, without a written approval of Chemiphar (U) Limited.
Chemiphar (U) Limited. Guarantees that all above mentioned results are obtained by use of methods identical or equal to official recognised test methods. The codes mentioned under Method refer to an Internal Identification or Standard test method used.
Data concerning the measurement uncertainty of the test methods (if applicable) is available in the laboratory.

If you have any doubt about the authenticity of this Certificate, please e-mail us at info@chemiphar.net